

**Arizona Department of Environmental Quality
Drinking Water Lead and Copper Analysis Reporting Form**

>>>> System Information <<<<

PWS ID# 04-054

PWS Name: Town of Hayden

Gary Cruz

(520) 356-7801

(520) 356-6334

Owner/Contact Person

Owner/Contact Phone Number

Owner/Contact Fax Number

SAMPLE COLLECTION POINT/ID:

- Zone/Distribution
- Other - Direct from source
 - Surface
 - Well

Contaminant	Lead (Pb)	Copper (Cu)
Action Level	0.015 mg/l	1.3 mg/l
Analysis Methods	200.8	200.8
Sample Type:	<u>Triennial</u>	<u>Triennial</u>

Sample Type:
 Triennial (3YR) Compliance
 Annual Compliance
 6 Month Initial Compliance

Specimen #	Collection Point	Sample Date	Analysis Completion Date	Lead (mg/L) (1030) Result	Analysis Completion Date	Copper (mg/L) (1022) Result
1710634-01(8C)	520 Velasco	09/26/2017	09/28/2017	0.00063	09/28/2017	0.17
1710634-02(8C)	125 1st Ave	09/26/2017	09/28/2017	<0.00050	09/28/2017	0.010
1710634-03(8C)	565 W 1 St	09/26/2017	09/28/2017	<0.00050	09/28/2017	0.0099
1710634-04(8C)	735 11st	09/26/2017	09/28/2017	0.0013	09/28/2017	0.017
1710634-05(8C)	691 Utah	09/26/2017	09/28/2017	<0.00050	09/28/2017	0.0051
1710634-06(8C)	197 Hillcrest AVE	09/26/2017	09/28/2017	<0.00050	09/28/2017	0.0095
1710634-07(8C)	232 Terrace ST	09/26/2017	09/28/2017	0.00061	09/28/2017	0.0061
1710634-08(8C)	559 Garfield Rd	09/26/2017	09/28/2017	<0.00050	09/28/2017	0.0045
1710634-09(8C)	254 lower Rd	09/26/2017	09/28/2017	<0.00050	09/28/2017	0.19
1710634-10(8C)	686 N. San Pedro	09/26/2017	09/28/2017	0.00056	09/28/2017	0.080

Lab ID# AZ0066

90th % Calc:

0.00056

0.17

I hereby certify that the information provided in this report is accurate and correct to the best of my knowledge.

Printed Name and Phone Number of Lab Contact: Max DiSante, Laboratory Director Phone # (520) 882-5880

Signature: *Max DiSante*

Mail completed form to: ADEQ Water Quality Compliance Data Unit (MC 5415B-1), 1110 W. Washington St. Phoenix, AZ 85007.
 For questions call: (602) 771-4513 or within AZ 1-800-234-5677 Ext. 4513. Fax: (602) 771-4505

Copies of this form are available at <http://www.azdeq.gov/function/forms/appswater.html#sdw>, scroll down to laboratory reporting forms and click on DWAR 8: DW Lead & Copper Analysis Report.

Revised: 8/2008

ADEQ

Arizona Department
of Environmental Quality



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ0404-054

DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 520 Velasco

Sample collection date: 09/26/2017

Analytical Lead result, in mg/L (milligrams per liter): 0.00083

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 358-7801

E-mail address at our public water supply system: townofhayden@coppernet.net



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ0404-054 DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 125 1st Ave
Sample collection date: 09/28/2017
Analytical Lead result, in mg/L (milligrams per liter): 0

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 356-7801

E-mail address at our public water supply system: townofhayden@coppernet.net



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ04-04-054

DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 565 W 1st St

Sample collection date: 09/28/2017

Analytical Lead result, in mg/L (milligrams per liter): 0

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 366-7801

E-mail address at our public water supply system: townofhayden@coppernet.net



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ0404-054 DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 735 11th St
Sample collection date: 09/26/2017
Analytical Lead result, in mg/L (milligrams per liter): 0.0013

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 358-7801

E-mail address at our public water supply system: townofhayden@coppernet.net



Arizona Department of Environmental Quality



Lead Consumer Notice (LCN)
Arizona Department of Environmental Quality

PWS ID #: AZ04 04-054 DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 691 Utah
Sample collection date: 09/26/2017
Analytical Lead result, in mg/L (milligrams per liter): 0

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 356-7801

E-mail address at our public water supply system: townofhayden@coppemet.net



Arizona Department of Environmental Quality



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ0404-054 DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 197 Hillcrest Ave

Sample collection date: 09/26/2017

Analytical Lead result, in mg/L (milligrams per liter): 0

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 358-7801

E-mail address at our public water supply system: townofhayden@coppernet.net



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ0404-054 DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 232 Terrace St
Sample collection date: 09/26/2017
Analytical Lead result, in mg/L (milligrams per liter): 0.00081

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 356-7801

E-mail address at our public water supply system: townofhayden@coppernet.net



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ0404-054 DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 559 Garfield Rd
Sample collection date: 09/26/2017
Analytical Lead result, in mg/L (milligrams per liter): 0

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 356-7801

E-mail address at our public water supply system: townof hayden@coppernet.net



Arizona Department of Environmental Quality



Lead Consumer Notice (LCN)

Arizona Department of Environmental Quality

PWS ID #: AZ04-04-054

DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 254 Lower Rd

Sample collection date: 09/28/2017

Analytical Lead result, in mg/L (milligrams per liter): 0

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 356-7801

E-mail address at our public water supply system: [townof hayden@coppemet.net](mailto:townofhayden@coppemet.net)



PWS ID #: AZ0404-054 DATE: 10/02/2017

PWS NAME: Town of Hayden

ANALYTICAL RESULT FOR LEAD TAP WATER MONITORING

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: 686 N. San Pedro
Sample collection date: 09/26/2017
Analytical Lead result, in mg/L (milligrams per liter): 0.00058

Definitions

The MCLG or Maximum Contaminant Level Goal for lead is zero and the action level is 15 ppb. The MCLG is the level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. The action level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

What are the health effects of lead?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Town of Hayden] is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

How can I reduce exposure to lead?

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (602) 771-9200 or at <http://www.epa.gov/safewater/lead>. When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (520) 356-7801

E-mail address at our public water supply system: townofhayden@coppernet.net



Lead Consumer Notice (LCN) Certification Form

PWS ID #: AZ04 -04-054

PWS NAME: Town of Hayden

Monitoring period to which the notice applies: 2014 - 2017

Date(s) results were received from laboratory: 10/02/2017

Date(s) results were provided to consumers: 10/03/2017

The water system named above hereby certifies that its lead consumer notice has been provided to each person it serves at the specific sampling site from which the sample was tested. The water system also certifies that these results and the following information were provided to such persons within 30 days of receiving the test results from the laboratory:

- Individual tap results from lead tap water monitoring carried out under the requirements of 40 CFR §141.86.
- An explanation of the health effects of lead.
- Steps that consumers can take to reduce exposure to lead in drinking water.
- Contact information for our water utility.
- The maximum contaminant level goals and action levels for lead, and the definitions of these two terms.

Certified by:

Name: David J. Garcia

Title: Certified Operator

Phone # 520-483-9462

Date: 10/02/2017

(Instructions on Back)