



Consumer Confidence Report for Calendar Year 2021

Este informe contiene información muy importante sobre el agua usted bebe.
Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number		Public Water System Name	
AZ04-04-054		Town of Hayden	
Contact Name and Title		Phone Number	E-mail Address
David J. Garcia		520-483-9462	Davegarcia236@yahoo.com
We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>Town Hall</u> at <u>520-3567801</u> for additional opportunity and meeting dates and times.			

Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s): [ASARCO Hayden Well Field, Basin: Lower San Pedro, Sub Basin: Mammoth, Watershed: Lower Gila River](#)

Consecutive Connection Sources

A public water system that receives some or all of its finished water from one or more wholesale systems by means of a direct connection or through the distribution system of one or more consecutive systems. Systems that purchase water from another system report regulated contaminants detected from the source water supply in a separate table.

PWS # [AZ04-04-012 ASARCO LLC](#) and PWS # [AZ04-04-001 ASARCO Hayden Smelter](#) provides us a consecutive connection source of water.

Drinking Water Contaminants

Microbial Contaminants: Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Organic Chemical Contaminants: Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

Inorganic Contaminants: Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

Radioactive Contaminants: That can be naturally occurring or be the result of oil and gas production and mining activities.

Pesticides and Herbicides: Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

- Based on the information currently available on the hydrogeologic settings of and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this public water system, the department has given a low risk designation for the degree to which this public water system drinking water source(s) are protected. A low risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection. Further source water assessment documentation can be obtained by contacting ADEQ.

Definitions

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water	Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method
Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present	Millirems per year (MREM): A measure of radiation absorbed by the body
Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria was present	Not Applicable (NA): Sampling was not completed by regulation or was not required
Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements	Not Detected (ND or <): Not detectable at reporting limit
Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water	Nephelometric Turbidity Units (NTU): A measure of water clarity
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health	Million fibers per liter (MFL)
Maximum Residual Disinfectant Level (MRDL): The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap	Picocuries per liter (pCi/L): Measure of the radioactivity in water
Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur	ppm: Parts per million or Milligrams per liter (mg/L)
	ppb: Parts per billion or Micrograms per liter (µg/L)
	ppt: Parts per trillion or Nanograms per liter (ng/L) ppm x 1000 = ppb
	ppq: Parts per quadrillion or Picograms per liter (pg/L) ppb x 1000 = ppt
	ppt x 1000 = ppq

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Town of Hayden is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination	
E. Coli	N	0	0	0	0	Human and animal fecal waste	
Fecal Indicator (From GWR source) (coliphage, enterococci and/or E. coli)	N	0	0	0	0	Human and animal fecal waste	
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	0.63 MG/L	0.48 – 0.78	4	4	1-12/2021	Water additive used to control microbes
Chlorine dioxide (ppb) if treated with CLO2				800	0		Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination

		Detected					
Haloacetic Acids (HAA5) (ppb)	N	8.5 UG/L	6.4 - 8.5 UG/L	60	N/A	09/2021	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	71 UG/L	47 - 71 UG/L	80	N/A	09/2021	Byproduct of drinking water disinfection
Bromate (ppb) <small>if treated with Ozone</small>				10	0		Byproduct of drinking water disinfection
Chlorite (ppm) <small>if treated with CLO2</small>				1	0.8		Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90th Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	0.15 MG/L	0	1.3	1.3	08/2020	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	0.8 UG/L	0	15	0	08/2020	Corrosion of household plumbing systems; erosion of natural deposits

Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions
<i>(Example: Reporting failure)</i>	<i>(Example: Forgot to sample for RTCR)</i>	<i>(Example: 14 days)</i>	<i>(Example: Sent in May results to show that the system is not serving contaminated water)</i>

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.